



NOTES:

1. DESIGN AND CONSTRUCTION OF ROCK WALL SHALL CONFORM TO THE REQUIREMENTS OF THE CITY OF CEDAR PARK TRANSPORTATION CRITERIA MANUAL FOR MINIMUM SIGHT DISTANCE.
2. CONCRETE SHALL CONFORM TO ITEM 403, "CONCRETE FOR STRUCTURES".
3. WEEP HOLE SPACING SHALL BE AS DIRECTED BY THE ENGINEER.
4. WATER AND WASTEWATER SERVICE LINES TO BE INSTALLED WHEN THE WALL IS CONSTRUCTED. PVC MARKER PIPE TO BE LOCATED AT THE END OF THE PLUGGED SERVICE LINES.
5. THE BASE OF THE ROCK WALL MAY ABUT THE PROPERTY LINE WHERE WATER AND WASTEWATER SERVICES ARE NOT INSTALLED.

CITY OF CEDAR PARK PUBLIC WORKS DEPARTMENT		MORTARED ROCK WALL	
DARWIN MARCHELL, P.E.		STANDARD NO.	
10/1/01		623S-1	
ADOPTED		THE ARCHITECT/ENGINEER ASSUMES RESPONSIBILITY FOR APPROPRIATE USE OF THIS STANDARD.	